

## EC-CERTIFICATE OF CONSTANCY OF PERFORMANCE

### 1415–CPR–40- (C-1/2016)

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Smoke and heat control system, Smoke duct sections**

**Galvanized steel smoke and heat exhaust ventilation system**

Fire resistance	<b>E<sub>600</sub> 180 (h<sub>o</sub>) S 1000 single</b> <b>E<sub>600</sub> 180 (v<sub>e</sub>) S 1000 single*</b>
Maximum dimensions	rectangular cross-section: 2000 × 1000 mm (w x h) circular cross-section: Ø1000 mm

\*based on the criteria of the test standard EN 1366-9 and the test performed according to clause 5.2 of the product standard EN 12101-7

relates to a construction product, which has the above performance and the following intended use

*Smoke control and Fire safety*

and produced by

**RECYCLING Mérnöki, Gazdasági Bt. (Ryng Bt.)**  
**H-1173 Budapest, Flamingó köz 4., Hungary**

and produced in the manufacturing plant

**RECYCLING Mérnöki, Gazdasági Bt. (Ryng Bt.)**  
**H-1173 Budapest, Flamingó köz 4., Hungary**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard **EN 12101-7:2011** under system (1) are applied and that

***the product fulfils all the prescribed requirements set out above.***

This certificate was first issued on 08.02.2016 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Issue: 4.

Dated at Szentendre, 25<sup>th</sup> May 2020.



Ágnes Molnár  
Head of Certification Office